



ETA Heiztechnik GmbH
Gewerbepark 1
4716 HOFKIRCHEN
AUSTRIA

Wieselburg, 11 December 2006

Your reference/Your reference number
Your message
-
-

Our reference number
BLT 1577/06

Our reference
Ing. La/Kr

Cover note

Based on the test results:

BLT-reference number	BLT-approval number	heating boiler automatically stocked (chipped wood)
048/03	048/03	ETA Hack 25
152/03	049/03	ETA Hack 50
186/03	005/04	ETA Hack 90
187/03	047/03	ETA Hack 20

the heating boilers, automatically stocked, fired by chipped wood are permitted to carry the test label of the BLT – Biomass – Logistics – Technology Francisco Josephinum, which documents that it performs according to class III for efficiency (EN 303-5, section 4.2.1, figure 1) and class III for emissions (EN 303-5 table 7).

The director for
research and innovation:

HR Dipl.-Ing. Dr. Johann SCHROTTMAIER



For the
accredited testing station:

Dipl.-HLFL-Ing. Leopold LASSELSBERGER