



ETA Heiztechnik GmbH
Gewerbepark 1
4716 HOFKIRCHEN
AUSTRIA

Wieselburg, 11 December 2006

Your reference/Your reference number
Your message

-
-

Our reference number

BLT 1576/06

Our reference

Ing. La/Kr

Cover note

Based on the test results:

BLT-reference number	BLT-approval number	heating boiler hand stocked
018/98	028/99	Stückholzkessel ETA SH 30
015/00	007/00	Stückholzkessel ETA SH 60
047/03	035/03	Stückholzkessel ETA BK 15
078/03	036/03	Stückholzkessel ETA BK 29/35

the heating boilers, hand stocked, fired by log wood are permitted to carry the test label of the BLT – Biomass – Logistics – Technology Francisco Josephinum, which documents that it performs according to class III for efficiency (EN 303-5, section 4.2.1, figure 1) and class III for emissions (EN 303-5 table 7).

The director for
research and innovation:



For the
accredited testing station:

HR Dipl.-Ing. Dr. Johann SCHROTTMAIER

Dipl.-HLFL-Ing. Leopold LASSELSBERGER

